

# Inspection Certificate



Certificate No **968/INS 188.00/19**

Client / Certificate Owner  
Albrecht Automatik GmbH  
Industriestraße  
50529 Pulheim  
Germany

Product  
Albrecht Safety Valves

Type designation  
ASV-N, ASV-K, ASV-P, ASV-B (DN15 - 25, PN 40, soft seat)  
ASV-K (DN 15 - 25, PN 40, metallic seat)  
KVAZ (DN 32 - 65, PN 16, soft seat)  
KVAZ/S (DN 32- 65 , PN 16, soft seat)

Standards applied for inspection  
DIN EN ISO 10497:2010-06  
API 607:2016


Inspection Results  
The valve types have been tested successfully regarding Fire Safe according to DIN EN ISO 10497:2010 and API 607:2016 under surveillance of an expert of TÜV Rheinland Industrie Service GmbH.

The listed valves of the ASV-... series differ only in their drive unit. The valve body is identical within the series.  
The listed valves of the KVAZ and KVAZ/S series differ only in their drive unit. The valve body is identical within the series.

Inspection Period  
2019-04-09 - 2019-04-16

Cologne, 2019-04-30

TÜV Rheinland Industrie Service GmbH  
Am Grauen Stein,  
D-51105 Köln

 **TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Dipl.-Ing. Gebhard Bouwer

Inspection Body of TÜV Rheinland Industrie Service GmbH -  
Business Area Energy Systems and Automation  
Business Field Automation - Functional Safety, [www.tuvasi.com](http://www.tuvasi.com)